



DEPARTMENT OF COMMUNITY PLANNING, HOUSING AND DEVELOPMENT
Neighborhood Services Division

Courthouse Plaza One 2100 Clarendon Boulevard, Suite 700 Arlington, VA 22201
TEL 703.228.3830 FAX 703.228.3834 www.arlingtonva.us

VIOLATION NOTICE

Premises in Violation **800 South Buchanan Street
Arlington, Virginia 22204**

Reference No. CE050348

Responsible Party: **BARCROFT SCHOOL & CIVIC
LEAGUE THE
800 South Buchanan Street
Arlington, VA 22204**

Date: 04/13/2005

c/o Eric Harold, President
BSCL
902 South Buchanan Street
Arlington, VA 22204

Date of Violation: 12/02/2004

Compliance Deadline: 05/25/2005

An inspection of the above premises has disclosed violations of Arlington County codes as shown below. You are directed to correct these violations by the compliance deadline indicated. A re-inspection will be made at that time if correction has not been made, further action will be taken as provided by the applicable ordinance(s).
If extenuating circumstances exist, the compliance deadline may be extended. Requests for extension must be made in writing and received at least three days before the deadline. *
You may obtain additional information by calling the office between 8:00 A.M. and 5:00 P.M. Inspectors may be reached between 8:00 and 9:30AM and 4:00 and 4:30 P.M.
You have the right to appeal to the Board of Appeals, provided that a written appeal is filed within twenty days after the notice is served.

<u>CODE OR ORDINANCE</u>	<u>VIOLATION</u>	<u>CORRECTIVE ACTION NECESSARY</u>
VUSBC/International Property Maintenance Code 2000, Section IPM 303.2	Exterior wood surfaces not in good condition.	Peeling, flaking, and chipped paint shall be eliminated and surfaces repainted .
Zoning Ordinance, Section 31A	Deterioration of exterior wall paint so as to produce a detrimental effect upon the character of the historic district	Paint as required

NOTE:

If applicable, you are advised to contact the County Building Inspections Section to determine permits necessary.
*For further information on appeal procedures, call 703-228-3830.

Rec'd _____
Signed _____

Marlene Terreros-Oronao, HP Code Inspector

cc: Michael Leventhal, HP Coordinator
File